



Supplier of Control Instrumentation to the South African Electrical Industry

BNP RATIO PERFORMANCES

| | | BURDEN | | | | | | | | | |
|-------|-----|--------|--------|-----|-----|-----|-------|-----|----|----|--|
| | | BNP10 | | | | | BNP15 | | | | |
| | | INPUT | OUTPUT | 2.5 | 5 | 10 | 5 | 7.5 | 10 | 15 | |
| RATIO | 1 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 2 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 2.5 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 3 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 5 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 7.5 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 10 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 15 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 20 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 25 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 30 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 40 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 50 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 60 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 75 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 80 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 100 | 5 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 1 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 2 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| | 2.5 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | |
| 3 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 5 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 7.5 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 10 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 15 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 20 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 25 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 30 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 40 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 50 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 60 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 75 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 80 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |
| 100 | 1 | 1 | 1 | 1 | 0.5 | 0.5 | 1 | 1 | | | |